

Turtle's Mulching
Land Clearing

Owner/Operator
Anthony Johnson

615-464-3165

Serving Middle Tennessee!



Congratulations Quincie!



Quincie Winchester, daughter of Ernie and Vanessa Winchester of Smithville, will be graduating with her Master's Degree in Speech Language Pathology from Tennessee State University on May 4, 2018. Quincie graduated among the top of her class in 2011 from DeKalb County High School. She received a scholarship and chose to attend Middle Tennessee State University where she graduated Cum Laude in 2015 with her Bachelor of Science Degree in Speech Language Pathology and Audiology and will again be graduating with high honors. Upon completion of her master's degree, Quincie will go on to complete a Clinical Fellowship in Speech Language Pathology and begin her career as a professional Speech Language Pathologist.




Happy Birthday in Heaven, Jane

2018 MAY 2018

SUN	MON	TUE	WED	THU	FRI	SAT
	1	2	3	4	5	
6	7	8	9	10	11	12
13	14	15	16	17	18	19
20	21	22	23	24	25	26
27	28	29	30	31		

BROYHILL FRIGIDAIRE ACTION LANE



CANTRELL'S
FURNITURE & APPLIANCES

638 West Broad
Smithville, TN 37166-1199

Owners: Jerry Lee Cantrell
Jane Cantrell

Phone: (615) 597-7871

DOWELLTOWN-LIBERTY WATER SYSTEM WATER QUALITY REPORT FOR 2017

Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart below, we only detected 11 of these contaminants. We found all of these contaminants at safe levels.

What is the source of my water?

Your water, which is ground water, comes from the Ordovician carbonate aquifer (water bearing zone). Our goal is to protect our water from contaminants and we are working with the State to determine the vulnerability of our water source to potential contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving this water system. The SWAP Report assesses the susceptibility of untreated water sources to potential contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The Dowlletown-Liberty Water System sources rated as moderately susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment's summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at <https://www.tn.gov/environment/article/wr-wq-source-water-assessment> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting Johnny Keaton at the Dowlletown-Liberty Water System between 8:00 A.M. to 4:30 P.M. weekdays.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Johnny Keaton at 615-536-5170.

How can I get involved?

Our Water Board meets on the last Thursday of each month at 6:00PM at the Dowlletown City Hall. Please feel free to participate in these meetings.

Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all of these requirements. Results of unregulated contaminant analysis are available upon request. We want you to know that we pay attention to all the rules.

Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Dowlletown-Liberty Water System's water treatment processes are designed to reduce any such substances to levels well below any health concern. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Dowlletown-Liberty Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>

Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, pumping stations, tanks, fire hydrants, etc. to 615-536-5170.

Pharmaceuticals in Drinking Water

Flushing unused or expired medicines can be harmful to your drinking water. Learn more about disposing of unused medicines at <https://www.tn.gov/environment/article/sp-unwanted-pharmaceuticals>

What does this chart mean?

- **MCLG** - Maximum Containment Level Goal, or the level of a containment in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL** - Maximum Containment Level, or the highest level of a containment that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- **MRDL** - Maximum Residual Disinfectant Level or MRDL. The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- **MRDLG** - Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **AL** - Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **Below Detection Level (BDL)** - laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- **Non-Detects (ND)** - laboratory analysis indicates that the contaminant is not present.
- **Parts per million (ppm) or Micrograms per liter (µg/l)** - explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** - explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Picocuries per liter (pCi/L)** - picocuries per liter is a measure of the radioactivity in water.
- **Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.
- **Million Fibers per Liter (MFL)** - million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- **Nephelometric Turbidity Unit (NTU)** - nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **TT** - Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Detected	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria	No	0		2017		0	TT Trigger	Naturally present in the environment
Turbidity ²	No	.28	.02 - .77	2017	NTU	N/A	TT	Soil runoff
Fluoride	No	.40	.31 - .46	2017	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Sodium	No	9.47		2016	ppm	N/A	N/A	Erosion of natural deposits; used in water treatment
Nitrate (as Nitrogen)	No	1.64		2017	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Copper ³	No	90% .816		2015	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead ⁴	No	90% 1.68		2015	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
TTHM [Total trihalomethanes]	No	59.0 LRAA	12.0 - 97.5*	2017	ppb	N/A	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	No	17.2 LRAA	13.4 - 17.2	2017	ppb	N/A	60	By-product of drinking water disinfection.
Combined radium	No	0.74		2014	PCI/l	0	5	Erosion of natural deposits
Total Organic Carbon ⁴	No			2017	ppm	TT	TT	Naturally present in the environment
Chlorine	No	1.44 AVG	.6 - 2.0	2017	ppm	MRDLG 4	MRDL 4	Water additive used to control microbes.

¹99.7% of our samples were below the turbidity limit.

²During the most recent round of Lead and Copper testing, 0 out of 10 households sampled contained concentrations exceeding the action level.

³We have met all treatment technique requirements for Total Organic Carbon removal.

* A single exceedance of 97.5 parts per billion triggered quarterly sampling for Disinfection By-Products. All subsequent sample results indicate disinfection by-product levels below the MCL. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.